

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE		PAGE OF PAGES 1 3	
2. AMENDMENT/MODIFICATION NO. 0010		3. EFFECTIVE DATE 8-24-00		4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO. (If applicable)	
6. ISSUED BY US ARMY ENGR DIST NEW ORLEANS PO BOX 60267 NEW ORLEANS LA 70160-0267 SHEILA ENCLADE 504-862-1514		CODE		7. ADMINISTERED BY (If other than Item 6) US ARMY ENGR DIST, NEW ORLEANS ATTN: CEMVN-CT-R PO BOX 60267 NEW ORLEANS LA 70160-0267		CODE	
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP code)				(X)		9A. AMENDMENT OF SOLICITATION NO. DACW29-99-B-0011	
						9B. DATED (SEE ITEM 11) 09-02-98	
						10A. MODIFICATION OF CONTRACT/ORDER NO.	
						10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE					
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS							
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGE- MENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. ACCOUNTING AND APPROPRIATION DATA (If required)							
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.							
(X)		A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CON- TRACT ORDER NO. IN ITEM 10A.					
		B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO AUTHORITY OF FAR 43.103(b).					
		C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:					
		D. OTHER (Specify type of modification and authority)					
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) THE ABOVE NUMBERED SOLICITATION FOR SELA, DWYER ROAD DRAINAGE PUMPING STATION IMPROVEMENTS, ORLEANS PARISH, LA IS HEREBY AMENDED AS FOLLOWS: BID OPENING DATE BID OPENING DATE & TIME OF 7 SEPTEMBER 2000, 2:00 P.M., LOCAL TIME AT PLACE OF BID OPENING, REMAINS UNCHANGED.							
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)			
15B. CONTRACTOR/OFFEROR		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA		16C. DATE SIGNED	
_____ (Signature of person authorized to sign)				BY _____ (Signature of Contracting Officer)			

SECTION 15025

1. Page 2, paragraph 6.1. Insert new sub-paragraph 6.1.3 as follows :

“6.1.3 Qualifications. Equipment furnished under this section shall be of a design and manufacture that has been successfully used in similar applications. The manufacturer shall have furnished equipment for a minimum of five similar applications that have demonstrated record of successful operation for a minimum period of 5 years. Provide a list of such installations complete with installation description contact names, addresses and telephone numbers. This reference list shall be submitted with the shop drawings. Should the screens not be in compliance, the Contractor shall repair or replace any units as necessary to meet the specifications. Costs for unit repair and retesting shall be the Contractor’s responsibility. The mechanically cleaned bar screen shall be a Climber Screen Mechanical Bar Screen Model IVS manufactured by Infilco Degremont Inc. or by an approved equal that conforms to the specifications and drawings.”

SECTION 15121

- Page 2, paragraph 4. At the end of the paragraph, insert the following:

“The Contractor may furnish 84-inch inner diameter pipe as an alternative; provided the Contractor furnishes any adaptors required to connect to the 84-inch pipes on the Dwyer Road Discharge Tubes and Canal contract.”

SECTION 15162

1. Page 1, paragraph 2.3. In the 3rd and 4th lines, replace the final sentence with the following:

“The full load rating (1.0 service factor) shall be available at 60 degree C rise by resistance with a 40 degree C ambient temperature.”

2. Page 2, paragraph 2.6. At the end of the paragraph insert the following sentence:

“Unless recommended otherwise by the motor manufacturer, it is intended to start the motors on a minimum 65% reactor setting.”

3. Page 2, paragraph 3.2. In the 2nd line, replace “supplied from a common oil pot” with “as recommended by the motor manufacturer, with all oil lubricated bearings fed from a common oil pot.”

4. Pages 2 & 3, paragraph 4.2. In the 2nd and 3rd lines, delete the last sentence in its entirety.

5. Page 3, paragraph 4.6. At the end of the paragraph, insert the following:

“Power factor correction capacitors shall correct the full load running power factor of the motor to 88%, \pm 5%, and may be mounted in a free standing unit enclosure if too large for inclusion in the main terminal box. The Contractor shall provide necessary conduit, wiring, fusing, terminations, etc. to utilize free standing enclosures.”

SECTION 16001

1. Page 41, paragraph 1.34. Delete the title in its entirety and substitute “4 KV and 208Y/120 V Distribution”

2. Page 41, paragraph 1.34.a. Delete this paragraph in its entirety and replace with the following :

“a. General.

Provide two (2) 225 KVA dry type general-purpose transformers, 4160 V Delta Primary, to 208Y/120 V Secondary, GE Type Q-HV, 60 KV BIL, copper primary and secondary wirings, two (2) 2 ½ % taps above and below normal, 150 degree C rise over 40 degree C ambient or equivalent. Each transformer shall be cable fed to the 208Y/120 V double ended switchboard “LV1/LV2” through conduits routed beneath the mezzanine slab. Transformers shall be located external of the position shown on the drawings for the unitized panel approximately 8 feet away from each side of LV1/LV2 panels and outside of the ladders up to pump grills.”

3. Page 42, sub-paragraph 1.34.b.1. Delete this sub-paragraph in its entirety and replace it with:

“1.34.b.1. Reserved.”

4. Page 42, paragraph 1.34.b. Insert new paragraph 6 as follows:

“6. Provide group mounted GE Type ADS fused switch feeder devices as scheduled.”

5. Page 42, paragraph 1.34.c. Delete the title in its entirety and substitute “Manual Transfer Switch Panels PP and LP”.